



CONDUIT PIPE SUBMITTAL

Introduction:

This document outlines the specifications, certifications, and materials used in the manufacturing of QualPol HDPE Conduit Pipe. These details ensure clarity and compliance for all stakeholders.

Product Range:

- QualPol Conduit Pipe
- Available in sizes: ¾"-4" - SDR9, SDR11, SDR13.5, SCHEDULE 40, SCHEDULE 80

Manufacturing Facility:

Location: 946 W Main Street, Jerome, Idaho 83338

Materials Used:

- Virgin HDPE Resin:
 - A high-quality resin specifically designed for conduit applications. Technical data sheets for this resin are available upon request.
- Colorants with UV Protection:
 - UV-protected colorants that are heavy metal-free, ensuring long-lasting durability.
- 1250# Pull Tape:
 - Heavy-duty pull tape included for enhanced functionality.

Certifications & Compliance:

- ASTM F2160: QualPol Conduit Pipe is manufactured to meet ASTM F2160 dimensional specifications.
- No Regrind Policy: No regrind material is allowed on the premises to maintain high standards for NSF-certified drinking water pipe production.
- Build America, Buy America: Ensuring compliance with domestic content regulations.

Contact Information: For more information, technical support, or additional documentation, please contact: